

Single Booster Service Check List

Location	Description	Action	6 months	12 Months	18 Months	24 Months
1	Inlet filter	Inspect and clean inlet filter	X	X	X	X
2	Flow switch	Inspect operation and adjust to 1 green light.	X	X	X	X
3	Water Non return valve	Inspect operation of NRV		X	X	X
		Replace				X
4	Faults read out	Inspect and record last 5 faults with dates.	X	X	X	X
5	Pressure switch	Check O-ring condition top of sensor and check display for supply pressure, pump top pressure and temperature.	X	X	X	X

